

## REQUEST FOR QUOTATION ON CONSTRUCTION OF DIESEL TANK BASE / CONTAINMENT.

### LOCATION: IKEJA MILL DATE ISSUED: APRIL 27,2023

# THE BID MUST BE SUBMITTED ON OR BEFORE THURSDAY 4TH MAY 2023.



#### TO ALL INTERESTED VENDOR

#### **SPECIFICATION**

- THE TANK BASE IS TO BE CONSTRUCTED FOR A 10,000LTR DIESEL TANK.
- A CONTAINMENT CAPABLE OF RETAINING DIESEL IN EVENT OF LEAKAGE IS ALSO TO BE CONSTRUCTED.
- TANK BASE DIMENSION 500mm x 1500mm x 500mm HIGH
- THE TWO CONCRETE SLAB BASE IS TO BE REINFORCED
- CONCRETE CONTAINMENT DIMENSION 6300mm x 2400mm x 500mm HIGH
- GOOD FOUNDATION MUST BE PREPARED FOR THE
  CONTAINMENT WITH A WELL FLOORED INTERNAL AREA.
- CONCRETE HARDNER MUST BE ADDED TO ACHIEVE TIMELY
  CURING
- •

#### Job Terms:

- QUOTATION IS SUBJECT TO 5% WHT.
- THERE WILL BE NO ADVANCE PAYMENT.
- THE BID MUST BE SUBMITTED ON OR BEFORE THURSDAY 4TH MAY 2023.

#### NOTE:

BIDS ARE TO BE SUBMITTED ELECTRONICALLY THROUGH: lsfrfq@livestockfeedsplc.com

Signed: Buying Committee Secretary Buying Committee Chairman